



# Red River Authority of Texas

JERRY BOB DANIEL, President, Truscott  
TODD W. BOYKIN, Vice President, Amarillo  
PENNY C. CARPENTER, Secretary-Treasurer, Silverton  
STEPHEN A. THORNHILL, Assistant Secretary, Denison  
MICHAEL R. SANDEFUR, Texarkana  
GEORGE WILSON SCALING, II, Henrietta  
JOE L. WARD, Telephone

RANDALL W. WHITEMAN, General Manager  
FABIAN A. HEANEY, Assistant General Manager  
DANNA P. BALES, Executive Assistant  
LANA HEFTON, Controller

**October 28, 2021**  
**NOTICE OF DRINKING WATER**  
**TOTAL TRIHALOMETHANES VIOLATION**  
**RRA – Preston Shores Water System, ID No. 0910037**

The Texas Commission on Environmental Quality (TCEQ) has notified the Authority's Preston Shores Water System that the drinking water supplied by the system has exceeded the Maximum Contaminant Level (MCL) for TOTAL TRIHALOMETHANES (TTHMs), as set in the Commissions Drinking Water Standards.

The MCL for TTHMs is 0.080 milligrams per liter (mg/L). Compliance with these levels is based on a running annual average of quarterly sample results. Preston Shores Water Systems running annual average for TTHMs in the third quarter of 2021 from DBP2-01 was 0.137 mg/L and DBP2-02 was 0.140 mg/L.

This is not an emergency. However, some people who drink water containing trihalomethanes or haloacetic acids in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

The Authority is working with engineers looking for an alternative solution to resolve these MCL violations. The Authority will continue to send letters out until the running annual average is below the required MCL.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For further information, please contact Mr. Ron Mullins, Utility Regulatory Officer, at the Red River Authority of Texas at (940) 723-8697. You may also contact your District Manager, Mr. Jason Whaley, at (903)786-9303.

Sincerely,

**RED RIVER AUTHORITY OF TEXAS**

A handwritten signature in black ink that reads "Ronald A. Mullins".

Ron Mullins  
Utility Regulatory Officer

RAM:slf